AMENDMENT NO. 1 NOVEMBER 2014
TO
IS 16098 (PART 2) : 2013 STRUCTURED-WALL PLASTICS PIPING SYSTEMS FOR NON-PRESSURE DRAINAGE AND SEWERAGE — SPECIFICATION

PART 2 PIPES AND FITTINGS WITH NON-SMOOTH EXTERNAL SURFACE, TYPE B

(*Second cover page*, *Foreword*, *para* 3, *line* 5) — Insert 'and polypropylene' *after* 'polyethylene'.

(*Second cover page*, *Foreword*, *para* 3, *line* 8) — Insert 'and PP' *after* 'PE'.

(*Second cover page*, *Foreword*, *para* 4, *line* 4) — Substitute 'PVC-U, PE and PP materials' *for* 'PVC-U and PE materials'.

(*Page* 1, *clause* **1**, *para* 1, *line* 3) — Insert 'or PP' *after* 'PE'.

(*Page* 4, *Table* 1, *SI No*. (iii), *col* 2) — Substitute 'Thermal stability (oxidation induction test, OIT)2)' *for* the existing.

[*Page* 4, *Table* 1, *Footnote* 1)] — Insert the following new footnote:

'2) The requirement is only valid for pipes and fittings intended to be jointed in the field by fusing or welding.'

(*Page* 4, *clause* **6.3.3**, *line* 2) — Substitute 'Table 5' *for* 'Table 2'.

(*Page* 5, *Table* 4, *Title*) — Substitute 'PP' *for* 'PE'.

(*Page* 5, *Table* 5, *Title*) — Substitute the existing clause references under the table heading by the following:

'(Clauses 6.3.1, 6.3.3, 6.3.4.1, 6.3.5.1.4, 6.3.5.1.5 and 6.3.5.2)'

Amendment No. 1 to IS 16098 (Part 2) : 2013

(*Page* 6, *clause* **6.3.3**) — Substitute the following for the existing formula:

‘$d_{em,Min} \geq 0.994 \times d_e$

$d_{em,Max} \leq 1.003 \times d_e$’

(*Page* 6, *clause* **6.3.4.1**) — Substitute ‘Table 5’ *for* ‘Table 2’, wherever appearing in the clause.

(CED 50)

Publication Unit, BIS, New Delhi, India